

Government of Bihar
Public Health Engineering Department
Monthly Water Quality Monitoring Report


Date of Sampling :- 04.02.2025
Date of Testing :- 10.02.2025

District Name : Bhojpur
Sample Collected By :- Self

Division Name: P.H. Division, Ara

District Name : Bhojpur					Division Name: P.H. Division, Ara										Date of Testing :- 10.02.2025							Remarks
Sample Collected By :-Self						Parameters																
S.no	Block	Panchayat	Village	Location of Source	Ward No.	pH	Turb	EC	TDS	TH	Ca	Mg	Cl	Alka	Fe	NO ₃	SO ₄	F	As	Total Coli		
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	
1	Ara	Karisath	Karisath	Ursuline English Medium School		7.82	0.8	443	288	168	35.47	19.44	43.97	176	0.10	NT	NT	NT	BDL	Negative	Safe	
						6.5-8.5	1	-	500	200	75	30	250	200	1	45	200	1	0.01	-		
Permissible Limit In absence of alternative source						NR	5	-	2000	600	200	100	1000	500	NR	NR	400	1.5	NR	-		

*NT = Not Tested, BDL=Below Detection Limit


10/02/25
Research Assistant
(Chemist)
P.H. Division, Ara